



NOTES:

1. RADII FOR CURVED SIDEWALK SHALL BE BETWEEN 600' AND 1000'.
2. ALL RADII SHALL BE STAGGERED.
3. EASEMENT REQUIRED FOR SIDEWALK THAT EXTENDS BEYOND RIGHT OF WAY LINE.
4. SIDEWALK SHALL BE A MINIMUM OF 8" IN WIDTH ADJACENT TO CURB.
5. SIDEWALK SHALL BE 3' AWAY FROM CURB FACE EXCEPT AT CURB RETURNS AND BUS STOPS.
6. SIDEWALK LAYOUT ON PLANS IS CONCEPTUAL ONLY. APPROVAL OF THE FINAL SIDEWALK LAYOUT SHALL BE MADE IN THE FIELD AND ADJUSTED AS NECESSARY TO MEET FIELD CONDITIONS AS APPROVED BY THE INSPECTOR PRIOR TO FINAL CONSTRUCTION.
7. CONCRETE SHALL BE CLASS "C"



REVISIONS	
No.	DATE

DEPARTMENT OF PUBLIC WORKS
ENGINEERING DIVISION

APPROVED BY:
Timothy R. Johnson

TIMOTHY R. JOHNSON, P.E.
Public Works Director, City Engineer
R.C.E. No. 42843

DATE
11/10/15

City of La Quinta

MEANDERING
SIDEWALK

STANDARD
PLAN No.

245

SHEET
1 OF 1