


NOTE: IF 4" AND LARGER SEE THRUST BLOCK DETAIL.

NOTE:

1. EQUIPMENT TO BE INSTALLED AT A MINIMUM OF 12" FROM WALLS, BUILDINGS, ETC. INSTALL IN PLANTING AREA.
2. ALL ABOVE GROUND ASSEMBLY SHALL RECEIVE ONE (1) COAT RED LEAD PRIMER AND ONE (1) COAT PAINT
3. WHEN UNIT IS NEXT TO BUILDING, WALL, ETC., TEST COCKS TO BE ON OUTSIDE.
4. VERTICAL BRASS RISERS AND UNION MAY BE CHANGED TO GALV. / SCH 40 PIPE WITH WRITTEN PERMISSION OF WATER PERVEYOR.

| | | | | |
|---|-----------------------|---|--------------------------------------|----------------------|
| SCALE N.T.S. | REVISIONS NO. DATE | <i>La Quinta</i> GEM of the DESERT | DESIGN AND DEVELOPMENT DEPARTMENT | STANDARD PLAN NO. |
|  | | APPROVED BY: CITY OF LA QUINTA <i>Bryan McKinney</i> | BACKFLOW PREVENTER DETAIL | 783 |
| | | BRYAN MCKINNEY PUBLIC WORKS DIRECTOR/CITY ENGINEER R.C.E. NO. 49418 | | SHEET 1 OF 1 |