

N	\bigcirc	TF.S	
ıν	\mathbf{C}	-	١.

"h"

3'

4'

5'

6'

17"

20"

23"

29"

1) this design does **not** allow grade differentials of more than 6" on opposing sides of the wall. This is not a retaining wall.

Vertical

reinforcement #4 @ 48" O.C.

#4 @ 48" O.C.

#4 @ 48" O.C.

#4 @ 24" O.C

2) fence heights are regulated - consult zoning regulations before beginning construction.

Table "a"

- 3) no water course or natural drainage shall be obstructed.
- 4) grout Only the cells containing rebar. This wall is not designed for all cells to be grouted.
- 5) all rebar to be astm spec. A615, grade 40 minimum.
- 6) all rebar lap splices to be 24" minimum.
- 7) all masonry units to be astm C-90 grade N.
- 8) rebar to be centered in masonry cells.

SEE PAGE 2 FOR ADDITIONAL INFORMATION

DISCLAIMER:

Alternate designs may be possible when provided with an engineered analysis. Use of this standard design is at the user's risk and carries no implied or inferred guarantee against failure or defects.

All footings adjacent to slopes to be at least 5' to daylight as shown below.




Table "b"			
"h"	"w"	Vertical reinforcement	
3'	19"	#4 @ 48" O.C.	
4'	22"	#4 @ 48" O.C.	
5'	29"	#4 @ 48" O.C.	
6'	34"	#4 @ 24" O.C.	

Check with the Building Department to verify if a building permit is required.

When a permit is required, the following inspections are required:

- 1) FOOTING: Excavation trench clean with steelin place and supported 3" above and away from the surrounding earth/dirt.
- 2) REBAR/PRE-GROUT; Bond beam rebar and vertical rebar in place - inspection prior to placing grout.
- 3) FINAL; After grout is placed prior to any decorative cap placement.

